

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 124712  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37265

1. OWNER MELVYN MILLETT ADDRESS AT WELL LOCATION 201 E BLOSSER RANCH RD  
MAILING ADDRESS PO BOX 252 PAHRUMP  
PAHRUMP NV 89041-0252 Subdivision Name: GERALD MARTIN ROS County: NYE

2. LOCATION NW 1/4 SW 1/4 Sec 34 T 19S N/S R 53 E Latitude N36°15'18.2" UTM E  NAD 27  
PERMIT/WAIVER No. 29-601-02 Longitude W116°00'39.6" N  NAD 83/WGS 84  
Issued by Water Resources Parcel No.

3. WORKED PERFORMED  New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	15	-15
SAND & GRAVEL		15	25	-10
CLAY & GRAVEL		25	77	-52
CALICHIE	WB	77	105	-28
CLAY & GRAVEL		105	135	-30
CALICHIE	WB	135	160	-25
CALICHIE & GRAVEL	WB	160	200	-40

9. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>9-7/8</u> Inches	<u>0</u> Feet <u>200</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Fl. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>2.37</u>	<u>.248</u>	<u>200</u>	<u>240</u>
<u>6</u>	<u>.280</u>	<u>.188</u>	<u>+2</u>	<u>5</u>

Perforations:

Type of perforation SCREEN  
Size of perforation .032

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 0 to 52  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 52 to 200  Pumped  Poured  
Type: \_\_\_\_\_  
Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 7-Jan, 20 16  
Date completed: 7-Jan, 20 16

7. Water Level

Static water level: 60 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING  
Contractor

Address 1220 MANSE RD  
Contractor

PAHRUMP NV 89048

Nevada contractor's license number  
issued by the State Contractor's Board 47333

Nevada driller's license number issued by the  
Division of Water Resources/the on-site driller 2513

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date 1/11/2016

36.255096 NAD  
-116.0101391 27