STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124713
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.175 and NAC 534.140

NOTICE OF INTENT NO. 37304

1. OWNER JOHN & MARIA GUNDACKER
MAILING ADDRESS 1051 MICKEY ST
PAHRUMP NV 89048

ADDRESS AT WELL LOCATION 1381 W HURACAN ST
PAHRUMP
Pocket Lot Name U5 CALVADA VLY County NYE

2. LOCATION SW1/45 E1/4 Sec. 29 T 20S N S R 53 E
PERMIT/WAIVER No 40-511-11
Issued by Water Resources Parcel No.

Latitude N36°10'34.1" UTM ☐ NAD 27
Longitude W116°02'17.3" N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	90	-90
CALICHIE	WB	90	105	-15
CLAY		105	175	-70
CALICHIE	WB	175	190	-15
CLAY		190	220	-30
CALICHIE	WB	220	230	-10
CLAY		230	240	-10

DCNR/DWR/SNBO
RECEIVED
JAN 19 2016

Date started: 16-Jul, 20 15
Date completed: 16-Jul, 20 15

7. Water Level
Static water level: 89 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	3.96	.375	0	240

Perforations:
Type of perforation MACHINED
Size of perforation .032
From 160 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 55 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 55 to 240 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the [illegible] driller 2190
Signed [signature]
By driller performing actual drilling on site or contractor
Date 7/20/2015

USE ADDITIONAL SHEETS IF NECESSARY

36.1761775 NAD
-116.037279 27