

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 124716  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 72969

1. OWNER ROBERT NESHKOFF  
MAILING ADDRESS PO BOX 1531  
PAHRUMP NV 89041-1531

ADDRESS AT WELL LOCATION 2560 S MONEY ST  
PAHRUMP  
Subdivision Name: U3 CALVADA VLY County: NYE

2. LOCATION NW 1/4 SE 1/4 Sec 35 T 20S N/S/R 63 E  
PERMIT/WAIVER No. 41-102-34 Parcel No. \_\_\_\_\_

Latitude N36°10'1.37359" UTM E  NAD 27  
Longitude W115°59'6.9321" N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Stock  
 Municipal/Industrial  Monitor

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	5	-5
CALICHIE		5	35	-30
CLAY		35	75	-40
CALICHIE		75	100	-25
CLAY		100	118	-18
CALICHIE	WB	118	125	-7
CLAY		125	137	-12
CALICHIE	WB	137	150	-13
CLAY		150	175	-25
CALICHIE	WB	175	200	-25

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
200		200	

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
9-7/8	0	200	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.37	.248	0	200
6		.188	+2.5	5

Perforations: SCREEN  
Type of perforation \_\_\_\_\_  
Size of perforation .032  
From 140 feet to 200 feet

Annular Seal:  Yes  No  
 Neat Cement 0 to 53  Pumped  Poured  
 Cement Grout \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_  Pumped  Poured  
Gravel Pack:  Yes  No 53 to 200  Pumped  Poured  
Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Date started: 18-Nov , 20 15  
Date completed: 18-Nov , 20 15

7. Water Level 70 feet below land surface  
Static water level: \_\_\_\_\_  
Artesian Flow: \_\_\_\_\_ G.P.M. P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name GREAT BASIN DRILLING Contractor  
Address 1220 MANSE RD Contractor  
PAHRUMP NV 89048  
Nevada contractor's license number 47333  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2513  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 11/19/2015

USE ADDITIONAL SHEETS IF NECESSARY

36.1670862  
- 115.9844008  
NAD 27

(Rev. 10-95)