STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124760
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38569
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Richard Ochoa
MAILING ADDRESS 8320 Vibrant Dr. LVNV 89117
DETAILED ADDRESS AT WELL LOCATION Buena Vida st South of Kyle Canyon Hwy 89166
Subdivision Name: County: Clark

2. PLS LOCATION SE ¼ SE ¼ 8 Sec 19 N/S 59 E
PERMIT/WAIVER NO. 126-08-802-008
Issued by Water Resources Current Parcel No.
Latitude 36°18'27.26" UTM E ☐ NAD 27
Longitude 115°23'33.61" UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☑ Rotary ☐ RVC
☑ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Loose Rock + Gravel			0	5	5
Clay + Gravel / Rock			5	120	115
Cemented Rock + Gravel			120	420	300
Cemented Rock +		✓	420		
Gravel with					
Water Bearing Factures				610	190

DCNR/DWR/SNBC
RECEIVED
JAN 29 2016

Date started: 1-5 , 20 16
Date completed: 1-22 , 20 16

7. WATER QUALITIES
Static water level: 405 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: NA

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air	25	NA	2-Hrs

9. WELL CONSTRUCTION
Depth Drilled: 610 Feet Depth Cased: 610 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14 3/4	Inches	Surface	Feet	55	Feet
9 7/8	Inches	55	Feet	610	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28.06	.250 STEEL	Surface	55
6.9	5.22	SDR 17 PVC	Surface	610

PERFORATIONS:
Type of perforation: Factory Screen
Size of perforation: .32 inch X .25 inch 6 Row
From 510 Feet To 610 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☒ Sanitary Seal Surface to 55 Ft.
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout 35 Ft. to Surface ☐ Pumped ☒ Poured
☐ Bentonite Chips 35 Ft. to 55 Ft. ☐ Pumped ☒ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Budget Drilling LLC Contractor
Address 1170 Darcy Ln Pahrump NV 89060 Contractor
Nevada contractor's license number as issued by the *State Contractor's Board*: 0077029
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 1573
Signed: Dennis Brown
By driller performing actual drilling on site or contractor
Date: 1-28-2016

(Rev. 08-12)
(NSPO Rev 11-12)
USE ADDITIONAL SHEETS IF NECESSARY

36.3076068
-115.3918259
NAD (O) 627
27

12-16-2016 BY DSB