STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124761
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38166
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Chris Garamendi
MAILING ADDRESS 1601 Rushing LV 89103
DETAILED ADDRESS AT WELL LOCATION 8780 Rocky LV NV
Subdivision Name: *County:* Clark

2. PLS LOCATION NW¼ NE ¼ 5 Sec 19 N/S 60 E
PERMIT/WAIVER NO. 125-05-504-011
Issued by Water Resources *Current Parcel No.*
Latitude 36.33278 UTM E ☐ NAD 27
Longitude 115.2867573 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Gravel			0	255	
Gravel + Water			255	263	
Gravel			263	300	
Gravel + Water			300	360	

DCNR/DWR/SNEO
RECEIVED
JAN 22 2016

Date started: 1-18, 20 16
Date completed: 1-22, 20 16

7. WATER QUALITIES
Static water level: 190 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled: 360 Feet Depth Cased: 360 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12¼	Inches	0	Feet	60	Feet
9 7/8	Inches	60	Feet	360	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+2 plus	60
~~9 7/8~~	60	40 Sch Pvc	+1	360

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 18
From 300 Feet To 340 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☒ Sanitary Seal 0 to 60
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout to ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Vernon H. Dimick
Contractor
Address 13040 Horse Dr LV NV
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 10062
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 552
Signed: V. H. Dimick
By driller performing actual drilling on site or contractor
Date: 1-22-2016

(Rev. 08-12)
(NSPO Rev 11-12)
USE ADDITIONAL SHEETS IF NECESSARY

36.3328142
-115.2859115
NAD 27
(O) 627

09-02-2016 BY DSB