STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124766
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37336

1. OWNER CAMINO DEL RIO SPEND THRIFT TRUST
MAILING ADDRESS PO BOX 4780
PAHRUMP NV 89041

ADDRESS AT WELL LOCATION 3631 S WINCHESTER AVE
PAHRUMP
Subdivision Name: U5 CALVADA VLY by: NYE

2. LOCATION NE ¼ SW ¼ Sec 32 T 20S N/S R 53 E
PERMIT/WAIVER No. 40-571-02
Issued by Water Resources Parcel No.

Latitude N36°09'58.2" UTM E ☐ NAD 27
Longitude W11602'34.3°" N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & GRAVEL		0	50	-50
CLAY		50	137	-87
CALICHIE	WB	137	145	-8
CLAY		145	153	-8
CALICHIE	WB	153	160	-7
CLAY		160	168	-8
CALICHIE	WB	168	178	-10
CLAY		178	190	-12
CALICHIE	WB	190	200	-10

DCNR/DWR/SNDO
RECEIVED
FEB 10 2016

Date started: 4-Feb , 20 16
Date completed: 4-Feb , 20 16

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9-7/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.794	.248	0	200
6	12.84	.188	+1.5	-5

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 52 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 52 to 200 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 80 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP NV 89048
Nevada contractor's license number issued by the *State Contractor's Board* 47333
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2513
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2/4/2016

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY

NAD 27 36.1662052
-116.0420014