STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124777
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37828
WELL NAME (If applicable): MW-19

1. OWNER/CLIENT NAME CV Propco LLC
MAILING ADDRESS 3485 W. Harmon Ave. Las Vegas, NV 89103

DETAILED ADDRESS AT WELL LOCATION 4530 Polaris Ave Las Vegas, NV
Subdivision Name. County: Clark

2. PLS LOCATION NE ¼ SW ¼ 20 Sec 21 N/S 61 E
PERMIT/WAIVER NO. MO-3115 (Issued by Water Resources) 1162-20-302001 (Current Parcel No.)

Latitude 36.10806"N UTM E
Longitude 115.18534"W UTM N
☑ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☑ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Fill			0	1
Silty Sand			1	7
Silty Clay			7	9
Caliche			9	10
Clayey sand			10	14
Sandy clay w/gravel moist		16.6	14	24
Silty Clay			24	25
Silty Sand			25	26
Sandy clay w/gravel /silty clay			26	31
clayey silt			31	32
Silty clay/ very moist			32	36
Sandy clay w/ gravel wet			36	43
Clayey sand w/gravel			43	44
Silty Clay w/ gravel moist			44	46

SCNR/DWR/SNDO
RECEIVED
DEC 22 2015

Date started: 18-Dec, 20 15
Date completed: 18-Dec, 20 15

7. WATER QUALITIES
Static water level: 16.6 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
1		50 Mins

9. CONSTRUCTION
Depth Drilled: 46 Feet Depth Cased: 46 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	46	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.01	0.237	0	46

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☑ Bentonite Chips	35	to	39	☐ Pumped	☑ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☑ Sand Pack [< 0.2 in.]	39	to	46	☐ Pumped	☑ Poured
☑ Other, explain:	0	to	35	☑ Pumped	☐ Poured

1' sump bottom of screen/ 0-35' bentonite grout

PERFORATIONS:
Type of perforation: Factory
Size of perforation: ..020

From	Feet	To	Feet
40		45	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP (Contractor)
Address 4221 W. Oquendo Rd. Las Vegas, NV 89118 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2526
Signed: (Driller performing actual drilling on site or contractor)
Date: 12/21/2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.