DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 13031
Permit No.
Basin Truckee Meadows

1. OWNER D.W. Hood ADDRESS 5925 Del Monte Reno, Nevada

NW corner

2. LOCATION NE ¼ NW ¼ Sec. 1 T. 18N N/S R. 19 E. Washoe County

PERMIT NO. 5925 Del Monte Drive

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Broken rock w/ topsoil		0	1	1
Hard grey (or black) andesite		1	12	11
Hard fractured black andesite		12	62	50
Gray andesite alluviam to 2' diam. very clean & water bearing68-74	X	62	70	8

Date started 6-21-72, 19
Date completed 6-22-72, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
~~AIR BLOWN:~~	~~60GPM @ 70'~~		
	~~50GPM @ 60'~~		~~1½ hrs.~~

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 70 feet
Casing record
Weight per foot 12.82 Thickness .188

Diameter	From	To
6 5/80D inches	0 feet	70 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement slurry
Depth of seal 50'+ feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation oxy-acet. torch
Size perforation 3/16 X 4"
From 50 feet to 70 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 42 Feet below land surface
Flow G.P.M.
Water temperature cold °F. Quality not tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
Address 1955 18th Street; Sparks, Nev.
Nevada contractor's license number 9767
Nevada driller's license number 493
Signed W L McDonald
Date 6-23-72

USE ADDITIONAL SHEETS IF NECESSARY

5471