

Log No. 13035

Permit No. _____

Basin Washoe

WELL DRILLERS REPORT

Please complete this form in its entirety.

1. OWNER Frank Fox ADDRESS 120 Trinity Reno, Nevada

2. LOCATION 1/4 ~~1/4~~ Sec 17 T. 18 N/S R. 20 E. Washoe County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Rock & Soil		0	2	2
Cemented Rock		2	20	18
Sand & Gravel	X	20	24	4
Sand	X	24	30	6
Sandy Clay		30	36	6
Gravel	X	36	40	4
Sandy Clay		40	45	5
Sand & Gravel	X	45	85	40
Sandy Clay		85	87	2
Sand	X	87	94	7
Gravel	X	94	96	2

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 96 feet
 Casing record _____
 Weight per foot 12.89 Thickness .188
 Diameter From To
6 inches 0 feet 96 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Mill Slat
 Size perforation 3/32 X 3"
 From 68 feet to 96 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 6 Feet below land surface
 Flow _____ G.P.M.
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Burgess & Rehe Well Drilling Co.
 Address 3320 Cente Dr. Carson City, Nv.
 Nevada contractor's license number _____
 Nevada driller's license number 699
 Signed [Signature]
 Date 4-20-73

Date started 4/11/73
 Date completed 4/17/73

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Developed with Compressed Air</u>			
<u>Approx. 70 Gals. per minute</u>			

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours