DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 13043
Permit No. ~~31549~~
Basin 34023

1. OWNER HEINZ RETTIG ADDRESS P.O. BOX 5042 LAS VEGAS, NEV. 89111

2. LOCATION NE ¼ SE ¼ Sec. 8 T. 23 ~~N~~/S R. 61 E. CLARK Coun.
PERMIT NO. ~~31549~~ 34023

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CEMENTED GRAVEL		0	30	30
GRAVEL		30	60	30
SAND + GRAVEL		60	170	110
LARGE ROCKS		170	240	70
BLUE CLAY		240	255	15
SAND + COURSE ROCK		255	365	110
CHERT		365	390	25
SAND + GRAVEL		390	508	118

RECEIVED
NOV 30 1972
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

Date started OCT. 16, 1972
Date completed NOV. 9, 1972

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 50 Draw down 290 feet 5 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 500 fe
Casing record 8"
Weight per foot Thickness 3/16"

Diameter	From	To
8 5/8 inches	0 feet	500 fee
inches	feet	fee
inches	feet	fee
inches	feet	fee
inches	feet	fee
inches	feet	fee

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 fee
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 500' fee

Perforations:
Type perforation 1/4" x 6" TORCH
Size perforation 4 AROUND
From 220 feet to 500 fee
From feet to fee
From feet to fee
From feet to fee
From feet to fee

9. WATER LEVEL
Static water level 246 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true t the best of my knowledge.

Name ALLEN WATER WELL SERV.
Address 4847 VALLEY VIEW LV, NEV.
Nevada contractor's license number 5095
Nevada driller's license number 40
Signed [signature]
Date 12-22-72

USE ADDITIONAL SHEETS IF NECESSARY

5471