

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 13124
 Rec. _____ 19____
 Well No. _____
 Permit No. 26807
Do not fill in

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Owner Wallace E. Farr Driller Effinger Drill & Pump Service
 Address 2127 Christina Street NLV Address Box 579 City _____ Lic. No. 212
 Location of well: NE NW 2 22 61 T. _____ N/S, R. _____ E, in _____ County
 or 26807 Helm Drive Clark

Water will be used for Domestic Total depth of well 250 feet
 Size of drilled hole 12 inch Weight of casing per linear foot .1414
 Thickness of casing .156 Temp. of water _____
 Diameter and length of casing 8" ID 250 feet
 (Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)
 If flowing well give flow in c.f.s. or g.p.m. and pressure _____
 If nonflowing well give depth of standing water from surface 18'
 If flowing well describe control works _____ (Type and size of valve, etc.)
 Date of commencement of well August 12, 1963 Date of completion of well August 17, 1963
 Type of well rig "Walker-Neer 31"

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	4	4	Sandy Clay
4	12	8	Gyp
12	15	3	Limestone
15	21	6	Red Sandy Clay
21	27	6	White Clay & Gravel (Water)
27	60	33	Red Clay
60	70	10	Brown Clay
70	73	3	Lime (Water)
73	89	16	Brown Clay & Limestone
89	94	5	Lime (Water)
94	108	14	Red Clay
108	111	3	Lime (Water)
111	136	25	Red Clay
136	139	3	Sandstone
139	145	6	Red Sandy Clay
145	149	4	Gravel (Water)
149	160	11	Sandstone
160	174	14	Red Sticky Clay
174	178	4	Lime (Water)
178	180	2	Red Clay
180	250	70	Gravel (Water)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation) 180 to 250
 from _____ to _____ ft.
174-178
 Other aquifers 145-149
108-111
89-94
70-73

21

First water at _____ feet.

Casing perforated 130 to 245
 from _____ to _____ ft.

1/8" x 12" perforated torch

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8" ID	0	250	250	Cemented from 0 to 50 feet 1½ yards of cement Graveled packed from 50 to 245 feet 4½ yards of pea gravel

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Drill & Pump
Well Driller

By A. F. Effinger
License No. 212

Dated August 25, 19 63

(Not to be filled in by Driller)
