DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 13201
Permit No.
Basin Clover Val CARD

1. OWNER [illegible] ADDRESS Clover Valley Nevada

2. LOCATION SE ¼ ¼ Sec. 27 T. 35 N/S R. 62 E. Elko County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sandy Clay	no	0	4	4
Brown Sandy Clay	no	4	25	21
Brown Clay Gravel	yes	25	60	35
Gravel Sand	yes	60	67	7
Clay Gravel + Sand	yes	67	100	33
Brn Sticky Clay	no	100	115	15
Brown Sticky Clay	no	115	135	20
Brown Clay Cemented				
Gravel	no	135	174	19
Brn Sand Rock	no	174	176	2
Brn Sticky Clay + Gravel	yes	176	205	29
Brn Sandy Clay + Gravel	yes	205	211	6
Brn Sand Rock	no	211	213	2
Brn Clay + Gravel	yes	213	230	17
Brown Sandy Clay Tan				
Gravel	yes	230	238	8
Brown Clay + Gravel	no	238	255	17
Brn Clay Tan Gravel	yes	255	265	10
Brn Clay + Gravel	no	265	290	25
Gravel	yes	290	300	10
Rock Brn Clay	no	300	355	55
Brn Clay Gravel	yes	355	365	10
Brn Clay + Small Gravel	no	365	390	25
Brn Clay	no	390	400	10
Light Brn Clay Sand Gravel	yes	400	425	25
Brn Clay	no	425	450	25
Brn Sticky Clay	no	450	470	20

Date started 1-1, 1972
Date completed 5-3, 1973

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	300	300 ft	2 hours
Well not in use not sufficient water			

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 14 inches Total depth 565 feet
Casing record
Weight per foot ..... Thickness .250

Diameter	From	To
14 inches	0 feet	403 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Puddling Clay
Depth of seal 25 ft feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Factory
Size perforation 3/16"
From ..... feet to 403 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 6 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ralph W. Denton
Address Route 1 Twin Falls Idaho
Nevada contractor's license number 10409
Nevada driller's license number 704
Signed Ralph W. Denton
Date 5-25-73

USE ADDITIONAL SHEETS IF NECESSARY

5471