DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 13207
Permit No. 26675
Basin Dayton Seg CARD
31042

1. OWNER Thomas Eitel ADDRESS P.O. Box 109 - Dayton, Nev

2. LOCATION NE ¼ SW ¼ Sec. 17 T. 17 N/S R 23 E. LYON County
PERMIT NO. 26675

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☑ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay -		0	10	10
Cobbles		10	12	2
Clay -		12	24	12
Sandy Clay -		24	31	7
Sand + gravel	x	31	35	4
Cobbles in Clay		35	46	11
Alt. Layers, Sand				
grav. + Clay -		46	74	29
Cobbles in Clay		74	91	17
Streaks, Sand, grav				
+ Clay -		91	101	10
Sand, Fine -		101	104	3
Streaks, Sand + Clay		104	111	7
Clay -		111	114	3
Clay with thin Layers				
of Sand -		114	134	10
~~Clay~~ Sand -	x	134	146	11
Clay -		146	150	4
Clay - Cobbles imbed.		150	226	76
Hard Clay -		226	294	68
Sand -	x	294	296	2
Clay		296	300	-4

Date started ....., 19.....
Date completed ....., 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	204	161	8

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 26" inches Total depth 300 feet
Casing record .....
Weight per foot 44 LBS Thickness .250

Diameter	From	To
16 inches	+1 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☑ Type .....
Depth of seal ..... feet
Gravel packed: Yes ☑ No ☐
Gravel packed from Surface feet to 300 feet

Perforations:
Type perforation milled
Size perforation ¼ x 3
From 200 feet to 300 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 29 Feet below land surface .....
Flow ..... G.P.M. .....
Water temperature 62 ° F. Quality .....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ENLOE DRILLING COMPANY
Address 1450 Valley View Drive
Carson City, Nevada 89701

Nevada contractor's license number 4739

Nevada driller's license number 249

Signed [signature]

Date June 14-73

USE ADDITIONAL SHEETS IF NECESSARY

5471