



OFFICE USE ONLY
Log No. 13296
Permit No. 108
Basin. Mesquite Valley, 108

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER J. Binnewig ADDRESS _____

2. LOCATION $\frac{1}{4}$ Sec. 19 T. 15 N/S R. 25 E Lyon County
PERMIT NO. two miles west of Washburn, Nevada

3.	TYPE OF WORK			4.	PROPOSED USE			5.	TYPE WELL	
	New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	Other <input type="checkbox"/>		Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>		Cable <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>
	Deepen <input type="checkbox"/>			Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>				

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sand</u>		<u>0</u>	<u>30</u>	<u>30</u>
<u>gravel</u>		<u>30</u>	<u>98</u>	<u>68</u>
<u>clay</u>		<u>98</u>	<u>100</u>	<u>2</u>
<u>Total depth</u>			<u>100</u>	
<u>Well making</u>				
<u>water from</u>				
<u>1 ft to 98</u>				

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 100 feet
 Casing record _____
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>100</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 30 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 100 feet
 Perforations:
 Type perforation Factory
 Size perforation 3/2
 From 60 feet to 100 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 20 Feet below land surface
 Flow none G.P.M. 40-50
 Water temperature 48 ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge
 Name Lester Millard
 Address Box 608, Yerington, Nev
 Nevada contractor's license number 11089
 Nevada driller's license number 579
 Signed Lester Millard
 Date April 14, 73

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down 12 feet 4 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours