DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 13367
Permit No.
Basin Smith Valley

1. OWNER M. N. Gustavson ADDRESS 54 Venturacci Fallon, Nev.
Lot # 6, Valley View Subdivision

2. LOCATION Lot 7 ¼ ~~W~~ N ½ Sec. 10 T. 11 N. N/S R. 23 E. MDB Lyon County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed Granite & Rock	No	0	115	115
Solid Sandstone Rock	No	115	135	20
Coarse Sand and Gravel	Yes	135	143	8
Short clay Stratas and sand	No	143	164	21
Sand and Gravel	Yes	164	194	30

Date started 6-28-73, 19
Date completed 7-19-73, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
No Pumping			
Bailed 30 gallons per minute.			

BAILER TEST
G.P.M. 30 g.p.m. Draw down 10 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6" inches Total depth 194 feet
Casing record 194
Weight per foot Thickness 188

Diameter	From	To
6 inches	0 feet	194 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Saw Slot
Size perforation 1/16" x 2"
From 174 feet to 194 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 145 Feet below land surface 135
Flow G.P.M.
Water temperature 60 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Edmund Miller Drilling Co.
Address Smith, Nev. 89430
Nevada contractor's license number Applied For
Nevada driller's license number 718
Signed Edmund Miller
Date 8-15-73

USE ADDITIONAL SHEETS IF NECESSARY

5471