

OFFICE USE ONLY
 Log No. 13375
 Permit No. _____
 Basin Lovelock

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Nevada Nile Ranch ADDRESS P.O. Box 820, Lovelock, Nv.
 2. LOCATION 1/4 SE 1/4 Sec. 2 T. 21 N/S R. 21 E Perishing County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Soil		0	2	2
Sand	X	2	24	22
Grey Silty Clay		24	34	10
Black Silty Clay		34	41	7
Sand & Gravel	X	41	63	22
Sandy Clay		63	81	18
Grey Clay		81	85	4
Sand	X	85	112	27
Sandy Clay & Gravel		112	116	4
Sand & Gravel	X	116	138	22
Sandy Clay & Gravel		138	154	16
Sand & Gravel with				
Small Layers of Clay	X	154	196	42
Heavy Gravel	X	196	200	4

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 200 feet
 Casing record _____
 Weight per foot 25.15 Thickness .188

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Mill Slot
 Size perforation 3/32 X 3"
 From 151 feet to 195 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 12 Feet below land surface
 Flow _____ G.P.M.
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Burgess & Rehe Drilling Co.
 Address 3320 Cente Dr. Carson City, Nv.
 Nevada contractor's license number _____
 Nevada driller's license number 699
 Signed Row Burgess
 Date 8-23-73

Date started 8/14/1973
 Date completed 8/18/1973

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Developed with Compressed Air</u>			
<u>Approx 200 Gals. per minute</u>			
<u>Draw Down 3'</u>			

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours