

OFFICE USE ONLY  
Log No. 13457  
Permit No. 27735, 36230  
Basin.....

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Dave Duffy ADDRESS P.O. Box 67  
Wadsworth, Nevada

2. LOCATION 1/4 N.E. NW 1/4 Sec. 8 T. 28 N/S R. 34 E County  
PERMIT NO.....

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Angular cobbles w/silt		0'	2'	2'
Brown clay		2'	3'	1'
Weather brown rock w/some clay 20% & damp		3'	36'	33'
Gray rock-very hard fractured		36'	40'	4'
Lt. brown fractured rock		40'	41'	1'
Gray rock-very hard fractured		41'	44'	3'
Brown hard broken rock w/some clay		44'	47'	3'
Gray rock-very hard fractured		47'	66'	19'
Brown damp broken rock w/50% clay		66'	73'	7'
Gray fractured very hard rock-@ 120-122'				
Rock becomes a little more brown in color		73'	135'	62'
Brown broken rock (hard to very hard)				
Very lt. brown w/some clay. At 146' damp dark brown clay 1'		135'	202'	67'
Altered quartz w/fractures		202'	265'	63'
Very hard rock (like quartz monzonite)		265'	280'	15'

Date started 8-15-73, 19.....  
Date completed 8-23-73, 19.....

8. WELL CONSTRUCTION  
Diameter hole 8" inches Total depth 180' feet  
Casing record.....  
Weight per foot..... Thickness.....

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>180</u> feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes  No  Type cement grout  
Depth of seal 50 feet  
Gravel packed: Yes  No   
Gravel packed from..... feet to..... feet

Perforations:  
Type perforation Factory mill slot  
Size perforation 3/32 x 2 1/2

From	feet to	feet
.....	.....	.....
.....	.....	.....
.....	.....	.....
.....	.....	.....
.....	.....	.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>air blown</u>	<u>230</u>	<u>260'</u>	
	<u>310</u>	<u>275'</u>	

9. WATER LEVEL  
Static water level 2.1 Feet below land surface  
Flow..... G.P.M. 3.10  
Water temperature..... ° F. Quality.....

10. DRILLERS CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Company  
Address P.O. Box 404  
Sparks, Nevada 89431  
Nevada contractor's license number 9767  
Nevada driller's license number 493  
Signed W.L. McDonald es  
Date 8-27-73

BAILER TEST  
G.P.M. .... Draw down..... feet ..... hours  
G.P.M. .... Draw down..... feet ..... hours  
G.P.M. .... Draw down..... feet ..... hours