

Log No. 13512
 Permit No. _____
 Basin Washoe Val

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Security Homes ADDRESS 124 Wenden Street
Winton, White Pine Renov, Nevada
Washoe Valley
 2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 23 T. 17 N. R. 19 E. Washoe County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Soil</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>D. W. & clay</u>		<u>5</u>	<u>28</u>	<u>23</u>
<u>Sand</u>	<u>yes</u>	<u>28</u>	<u>35</u>	<u>7</u>
<u>Gravelly clay & det</u>		<u>32</u>	<u>61</u>	<u>29</u>
<u>Sand</u>	<u>yes</u>	<u>61</u>	<u>70</u>	<u>9</u>
<u>Clay</u>		<u>70</u>	<u>83</u>	<u>13</u>
<u>Sand & gravel</u>		<u>83</u>	<u>100</u>	<u>17</u>

8. WELL CONSTRUCTION

Diameter hole 1 1/2 inches Total depth 100 feet
 Casing record 6 7/8 to 100
 Weight per foot _____ Thickness .188
 Diameter 6 7/8 inches From 0 feet To 100 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 feet feet
 Gravel packed: Yes No
 Gravel packed from 100 feet to 50 feet
 Perforations:
 Type perforation Fracture
 Size perforation 1/13
 From 100 feet to 74 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 11 Feet below land surface
 Flow _____ G.P.M.
 Water temperature Cold ° F. Quality No Lead

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Shen Pump & Drilling
 Address P.O. Box 99 Steamboat Nev.
 Nevada contractor's license number 11139
 Nevada driller's license number 698
 Signed J. M. Shen
 Date Oct. 16, 1973

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 15 Draw down 15 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours