DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 13 571
Permit No.
Basin Golden Valley

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Couch #2 ADDRESS 9300 Williams ~~3425 Industrial Park Rd~~ Reno
Golden Valley

2. LOCATION: ¼ ¼ Sec. 25 T. 20 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☑ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Red Sandstone		0	55	55
Red Sandstone		55	93	38
Hard Grey Granite		93	108	15
L.D. Granite		108	110	2
Extra Hard Grey Granite				
Rock		110	122	12
L.D. Medium Grey Granite		122	134	12
Extra Hard D. Granite		134	154	20
Hard Grey Granite		154	176	22
Fine Grey D.C. Granite		176	205	29

Date started 5-3 1973
Date completed 5-10 1973

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
No pumping test			

BAILER TEST 40
G.P.M. 10 Draw down feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth feet
Casing record
Weight per foot Thickness 134

Diameter	From	To
4 inches	0 feet	205 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal: feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation
From 140 feet to 205 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 140 Feet below land surface
Flow Dry G.P.M.
Water temperature Cold °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Steve Pumps Drilling
Address P.O. Box 99, Steamboat Nevada
Nevada contractor's license number 11139
Nevada driller's license number 698
Signed J. M. Steve
Date 5-12-1973

USE ADDITIONAL SHEETS IF NECESSARY

5471

OFFICE
STATE ENGINEER

1973 OCT 18 AM 10 50