DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 1-3-5 Tel
Permit No.
Basin Golden Val

1. OWNER Don Sharp ADDRESS
916 Margaret
Golden Valley

2. LOCATION S.E. ¼ U.W. ¼ Sec. 10 T. 20 N/S R. 19 E. Washoe County

PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D-G hardpan		0'	52'	52'
Soft D-G w/some clay		52'	71'	19'
Very damp D-G w/3/4"				
semi angular gravels		71'	80'	9'
Weather granite-med.				
hard-brown		80'	94'	14'
Clay seam		94'	95'	1'
Weather granite-med.				
hard to hard		95'	137'	42'

Date started 9-21-73, 19
Date completed 9-22-73, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air blown	17.64	125'	

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 130 feet
Casing record 130'
Weight per foot 12.89 Thickness .188

Diameter	From	To
6 5/8 OD inches	0 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement grout
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Torch cut 3 rows
Size perforation
From 97 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 49 Feet below land surface
Flow G.P.M. 17.64
Water temperature 56 ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
Address P.O. Box 404 Sparks, Nevada 89431

Nevada contractor's license number 9767

Nevada driller's license number 493

Signed W. L. McDonald Jr.

Date 9-24-73

USE ADDITIONAL SHEETS IF NECESSARY

5471

[illegible]