DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 13563
Permit No.
Basin Lovelock

1. OWNER Bill Tresize ADDRESS
Lovelock, Nevada

2. LOCATION ¼ ¼ Sec. 16 T. 30 N/S R. 33 E. Pershing County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ air Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Find sand w/some clay & some brown clay lenses		0'	55'	55'
¼" angular gravels w/some clay		55'	70'	15'
Lt. brown clay		70'	73'	3'
Some brown clay w/sand & gravel to 3/4" & angular		73'	145'	72'

Date started 8-23-73, 19
Date completed 8-24-73, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air blown	49.5	135'	
	37.8	125'	

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6" inches Total depth 145 feet
Casing record 145'
Weight per foot 12.89 Thickness .188

Diameter	From	To
6 5/8 O.D. inches	0 feet	145 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement grout
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory mill slot
Size perforation 3/32x2½x40x1/8x2½x20
From 87 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 88 Feet below land surface
Flow G.P.M. 49.5
Water temperature 60 ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Company
Address P.O. Box 404
Sparks, Nevada 89431
Nevada contractor's license number 9767
Nevada driller's license number 493
Signed [signature]
Date 8-25-73

USE ADDITIONAL SHEETS IF NECESSARY

5471