DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 13651
Permit No. 26719
Basin

1. OWNER Richard Cantino ADDRESS Lathrop Wells, Nev. 89020

2. LOCATION 130' S NE 150' W ¼ Sec. 8 T. 16 N/S R. 49 E. Nye County
PERMIT NO. ~~Domestic~~ 26719

3. TYPE OF WORK			4. PROPOSED USE			5. TYPE WELL	
New Well	☒	Recondition ☐	Domestic	☒	Irrigation ☐ Test ☐	Cable	☐ Rotary ☒
Deepen	☐	Other ☐	Municipal	☐	Industrial ☐ Stock ☐	Other	☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		00'	3'	3'
Sandy Clay		3'	30'	27'
Sandy clay with intermittent boulders		30'	170'	167'
Sand & large gravel		170'	217'	48'

RECEIVED
JUL 14 1971
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

Date started June 10, 1971, 19
Date completed June 15, 1971, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 10 3/4 inches Total depth 217 feet
Casing record 10 X ~~8~~ 3/16
Weight per foot Thickness 3/16

Diameter		From		To	
10 3/4	inches	00	feet	217	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type Cemented
Depth of seal Approx. 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 217 feet

Perforations:
Type perforation Milled Machine
Size perforation 3/16 X 3"
From 217 feet to 127 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level Feet below land surface 160'
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Cook Drilling Co.
Address Box 244 Lathrop Wells, Nev. 89020
Nevada contractor's license number 5376
Nevada driller's license number 279
Signed Lewis C. Cook
Date July 12, 1971

USE ADDITIONAL SHEETS IF NECESSARY

5471