DIVISION OF WATER RESOURCES

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 13757
Permit No.
Basin.

1. OWNER Bill Dickering ADDRESS 526 N. 2nd St.
Approx. 290' W, 643' S. of Covina Calif. 91722
Cntr. of S. 28

2. LOCATION NE ¼ SW ¼ Sec. 28 T. 14 N/S R. 20 E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay	x	0	60	60
Sandy Clay	x	60	85	25
Sandy Clay, Gravel		85	110	25
Clay		110	125	15
Gravel		125	130	5
Sand	x	130	147	17
Clay		147	220	73

Date started Dec. 15, 19 73
Date completed Dec. 24, 19 73

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	25	3'	8
	(Air Lift)		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 147 feet
Casing record
Weight per foot Thickness .188

Diameter	From	To
6 5/8 inches	S. +2 feet	45 feet
inches	55 feet	75 feet
inches	85 feet	125 feet
inches	145 feet	147 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 45'
Gravel packed: Yes ☑ No ☐
Gravel packed from 45 feet to 147 feet

Perforations:
Type perforation Wire wound screen
Size perforation .040
From 45 feet to 55 feet
From 75 feet to 85 feet
From 125 feet to 145 feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Robertson Eng & Drill.
Address Carson City, Nev.
Nevada contractor's license number 11539
Nevada driller's license number 682
Signed Keith Robertson
Date Dec. 31, 1973

USE ADDITIONAL SHEETS IF NECESSARY

5471