DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 13768
Permit No.
Basin California Wash

1. OWNER C X PRODUCTS CORP ADDRESS BOX 29
MOAPA NV. 89025

2. LOCATION NW ¼ SE ¼ Sec. 2 T. 15 N/S R. 66 E. CLARK County
PERMIT NO.

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
QUARTZ		276	358	82
BROKEN QUARTZ	X	358	360	2
WELL DRILLED				
+ CASED PREVIOUS				
TO ~~11-22-73~~ 276	BY	OTHERS		
CEMENTED 0-150 FT				
WITH 4½ YDS				
CEMENT BY OTHERS				
WELL TESTED WITH				
AIR FOAM				
MAKING IN EXCESS				
OF 500 G.P.M.				

Date started 11-26, 1973
Date completed 11-26, 1973

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 360 feet
Casing record
Weight per foot Thickness

Diameter		From		To	
6 5/8	inches	260	feet	360	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation TORCH
Size perforation 1/8 X 4 ROWS
From 260 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 8 Feet below land surface
Flow G.P.M.
Water temperature 75 ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHAPARRAL DRLG & PUMPS
Address 4161 CANAL L.V. NV.
Nevada contractor's license number 10791
Nevada driller's license number 694
Signed [signature]
Date 11-26-73

USE ADDITIONAL SHEETS IF NECESSARY

5471