DIVISION OF WATER RESOURCES

STATE OF NEVADA

DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 13771
Permit No. 28045
Basin Truckee Meadows

WASHOE CO SCHOOL DIST
MAINTENANCE YARD
KLEPPE LANE

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

1. OWNER Capriotti Construction Company ADDRESS P.O. Box 2388 Reno, Nevada 80505

2. LOCATION West ¼ ¼ Sec. 11 T. 19 N N/S R. 20E E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top soil | | 0 | 16 | 16 |
| Solid rock | | 16 | 35 | 19 |
| Sand & gravel | | 35 | 78 | 43 |
| Blue clay | | 78 | 82 | 4 |
| Sand & gravel | | 82 | 125 | 43 |
| Sandy clay | | 125 | 130 | 5 |

Date started ....., 19.....
Date completed ....., 19.....

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| 850 | 200 | 19' | 8 hrs. |

Test pumped for 2 consecutive 8 hour days.

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 8" inches Total depth 130 feet
Casing record 8" - 12 gauge double hard red
Weight per foot ..... Thickness .....

| Diameter | From | To |
|---|---|---|
| 8" inches | +2 feet | -130 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type .....
Depth of seal 47 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Factory cut
Size perforation 1/8" X 3"
From -126 feet to -74 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 12' - 0' Feet below land surface .....
Flow ..... G.P.M. .....
Water temperature 64 ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Harry W Jones
Address 1468 So. Virginia Reno, Nev
Nevada contractor's license number 5307
Nevada driller's license number 285
Signed Reno Pump & Supply
Date December 28, 1973

USE ADDITIONAL SHEETS IF NECESSARY

5471