

OFFICE USE ONLY
 Log No. 13811
 Permit No. _____
 Basin Eagle Valley

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Millard Realty & Constr. Co. ADDRESS 224 S. Carson St.
Carson City, Nevada 89701

2. LOCATION SE 1/4 SE 1/4 Sec. 29 T. 15 N/S R. 20 E. Carson City County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Sandy Clay		2	30	28
Sand	X	30	32	2
Sandy Clay		32	105	73
Sand	X	105	125	20
Sandy Clay		125	135	10
Sand	X	135	150	15
Sandy Clay		150	154	4
Sand	X	154	170	16
Sandy Clay		170	174	4
Sand	X	174	190	16
Sandy Clay		190	195	5

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 195 feet
 Casing record _____
 Weight per foot 12.89 Thickness .188
 Diameter 6-5/8 inches From 0 feet To 195 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Grout
 Depth of seal 60 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Mill Slat
 Size perforation 3/32 x 3"
 From 156.5 feet to 190 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 35 Feet below land surface
 Flow None G.P.M.
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Burgess & Rehe Drilling Co.
 Address 3220 Cents Dr. Carson City, Nv.
 Nevada contractor's license number 12278
 Nevada driller's license number 699
 Signed [Signature]
 Date 2-6-74

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed with Compressed Air			
Approx. 80 Gals. per minute			

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours