

OFFICE USE ONLY
Log No. 13827
Permit No. 26849
Basin. Pine Creek

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Spring Creek ADDRESS Eeko

2. LOCATION S. 1/4 - 1.1 - 1/4 Sec. 27 T. 24 N/S R. 56 E. Eeko County

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other REVERSE

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay		0	120	
Reddish sandstone		120	245	
Light grey limestone		245	255	
White lime		255	320	
Greenish sandstone		320	325	
Large block solid limestone		325	380	
Thin stone		380	500	

8. WELL CONSTRUCTION
Diameter hole 22 inches Total depth 500 feet
Casing record
Weight per foot 33 LB Thickness 1/4
Diameter 12 inches From 0 feet To 500 feet
Surface seal: Yes No Type Cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 500 feet
Perforations:
Type perforation Valley floor
Size perforation 3/4" - 1 1/2" diameter
From 145 feet to 500 feet

Date started Aug. 21, 1972
Date completed Aug 27, 1972

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	900	128	8

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

9. WATER LEVEL
Static water level 60 Feet below land surface
Flow 900 G.P.M.
Water temperature 62° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Anthony Bros
Address 4710 Highway 40 - W - W - W
Nevada contractor's license number 5348
Nevada driller's license number 624
Signed Anthony Bros
Date Oct 1 - 1972