

OFFICE USE ONLY  
 Log No. 1389A  
 Permit No. \_\_\_\_\_  
 Basin Truckee Meadows  
CH20

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Alex Bullentini ADDRESS 1620 View Crest  
Reno, Nevada 89502  
S.W. Estates  
 2. LOCATION  $\frac{1}{4}$   $\frac{1}{4}$  Sec. 12 T. 18 N/S R. 19 E. Washoe County  
 PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders & clay		0'	5'	5'
Clean sand & gravels up to 3/4"-Semi-ang.		5'	15'	10'
1" Ang. grav. w/sand		15'	38'	23'
Very soft sandy formation		38'	50'	12'
Brown sandy clay		50'	67'	17'
Boulder		67'	69'	2'
Soft to med hard sandy formation		69'	82'	13'
1" red & black ang. gravels w/some lt. red clay-med. hard to hard		82'	105'	23'
Soft to med. hard red formation w/some clay		105'	122'	17'
Very soft-white sand		122'	125'	3'
Soft to med. hard 1" ang. gravels-black, becomes red @ 130'		125'	135'	10'
Formation becomes harder (med. hard)		135'	138'	3'
Formation becomes soft-boulders & cobbles		138'	155'	17'

8. WELL CONSTRUCTION  
 Diameter hole 6 inches Total depth 154 feet  
 Casing record 154  
 Weight per foot 12.89 Thickness .188  

Diameter	From	To
<u>6 5/8 OD</u> inches	<u>0</u> feet	<u>154</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation 3 rows torch cut  
 Size perforation \_\_\_\_\_  
 From 124 feet to 154 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3-14-74, 19\_\_\_\_\_  
 Date completed 3-18-74, 19\_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Air blown</u>	<u>25 @ 147'</u>		

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 125 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name W.L. McDonald & Co.  
P.O. Box 404  
 Address Sparks, Nevada 89431  
 Nevada contractor's license number 9767  
 Nevada driller's license number 493  
 Signed [Signature]  
 Date 3-20-74