

WELL DRILLERS REPORT

Please complete this form in its entirety

Log No. 13797
 Permit No. _____
 Basin Carson No. 16

1. OWNER P. W. Ramsden ADDRESS 1852 N. Division, Carson City, Nv. 89701

2. LOCATION Lot #6--Valley View #3
1/4 Sec. 12 T. 14 N/S R. 12 E Douglas County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Clay		2	8	6
Sandy Clay		8	24	16
Clay		24	35	11
Sandy Clay & Rock		35	42	7
Clay		42	62	20
Sandy Clay & Rock		62	71	9
Clay		71	98	27
Sand	X	98	101	3
Clay		101	128	27
Sand & Gravel	X	128	132	4
Sandy Clay		132	146	14
Decomposed Granite	X	146	150	4
Sandy Clay		150	157	7
Sand & Gravel	X	157	162	5
Decomposed Granite	X	162	165	3

8. WELL CONSTRUCTION
 Diameter hole 8-5/8 inches Total depth 165 feet
 Casing record _____
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>8-5/8</u> inches	0	165
_____ inches	_____	_____

 Surface seal: Yes No Type Groute
 Depth of seal 55 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Mill Slot
 Size perforation 3/32 X 3"
 From 128 feet to 160 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 85 Feet below land surface
 Flow _____ G.P.M.
 Water temperature Cold F. Quality Good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Burgess & Rohe Drilling Co.
 Address 3320 Conte Dr. Carson City, Nv.
 Nevada contractor's license number 12278
 Nevada driller's license number 699

Signed Charles Rohe
 Date March 26 - 1974

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed with Compressed Air			
Approx. 25 Gals. per minute			

BAILER TEST

G.P.M.	Draw down	feet	hours