

Log No. 13929
Permit No. _____
Basin. Pyramid Lake Val

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Pyramid Indian Tribal Enterprises ADDRESS Sutcliff, Nevada

2. LOCATION 1/4 Sec. 15 T. 24 N/S R. 23 E Washoe County
PERMIT NO. _____

| | | | | | | | | | |
|-----------------|--|--------------------------------------|-----------------|--|-------------------------------------|--------------------------------|--------------|--------------------------------|--|
| 3. TYPE OF WORK | New Well <input checked="" type="checkbox"/> | Recondition <input type="checkbox"/> | 4. PROPOSED USE | Domestic <input checked="" type="checkbox"/> | Irrigation <input type="checkbox"/> | Test <input type="checkbox"/> | 5. TYPE WELL | Cable <input type="checkbox"/> | Rotary <input checked="" type="checkbox"/> |
| | Deepen <input type="checkbox"/> | Other <input type="checkbox"/> | | Municipal <input type="checkbox"/> | Industrial <input type="checkbox"/> | Stock <input type="checkbox"/> | | Other <input type="checkbox"/> | air |

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|------|------|------------|
| loamy top soil w/ some clay | | 0' | 2' | 2' |
| Claylike hardpan | | 2' | 3' | 1' |
| Clean gravels & cobbles-cobbles to 6" | | 3' | 14' | 11' |
| Brown sandy clay w/ angular grav. w/ occas. cobbles-some fine sand lenses to 3' | | 14' | 54' | 40' |
| Hard boulders & cobbles-multi colored-some clay, lt. brown | | 54' | 56' | 2' |
| Some cobbles to 4" w/ grav. to approx. 1" soft, some clay, adobe brown, 30% | | 56' | 115' | 59' |
| Dark red & black grav. to 1" w/ coarse sand, soft w/ greenish clay | | 115' | 153' | 38' |
| Same gravels but formation harder | | 153' | 159' | 6' |
| Hard to very hard black rock | | 159' | 173' | 14' |
| Very hard black rock formation med. hard to hard-frac. blk. rock | | 173' | 202' | 29' |
| Very hard black rock | | 202' | 206' | 4' |
| | | 206' | 214' | 8' |

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 347 feet
 Casing record 347'
 Weight per foot 17 Thickness 188

| Diameter | From | To |
|---------------------|---------------|-----------------|
| <u>8 5/8</u> inches | <u>0</u> feet | <u>347</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type Cement grout
 Depth of seal 55 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation 5 rows torch cut & EMS
 Size perforation _____
 From 100 feet to 347 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 3-21-74, 19____
Date completed 3-27-74, 19____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-----------|-----------------|-----------|------------------|
| Air blown | 30 to 50 @ 200' | | |
| | | | |
| | | | |

9. WATER LEVEL

Static water level 70 Feet below land surface
 Flow _____ G.P.M.
 Water temperature 57 ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
P.O. Box 404
 Address Sparks, Nevada 89431

Nevada contractor's license number 3767
 Nevada driller's license number 493

Signed [Signature]
 Date 4-2-74

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Pyramid Indian Tribal Enterprises ADDRESS Sutcliffe, Nevada

2. LOCATION 1/4 1/4 Sec. T. N/S R. E. County PERMIT NO.

3. TYPE OF WORK: New Well, Recondition, Deepen, Other
4. PROPOSED USE: Domestic, Irrigation, Municipal, Industrial, Stock
5. TYPE WELL: Cable, Rotary, Other

6. LITHOLOGIC LOG table with columns: Material, Water Strata, From, To, Thickness. Includes entries like 'Soft brown formation', 'Very hard black rock', 'Med. hard to hard black angular gravels to 1/2"', etc.

8. WELL CONSTRUCTION: Diameter hole, Total depth, Casing record, Weight per foot, Thickness, Surface seal, Depth of seal, Gravel packed, Perforations.

Date started, 19... Date completed, 19...

7. WELL TEST DATA table with columns: Pump RPM, G.P.M., Draw Down, After Hours Pump

9. WATER LEVEL: Static water level, Flow, Water temperature

10. DRILLERS CERTIFICATION: This well was drilled under my supervision... Name, Address, License numbers, Signed, Date

BAILER TEST: G.P.M., Draw down, feet, hours