

Log No. 13987
 Permit No. _____
 Basin Engle Valley

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Patrick N. Bacon ADDRESS P.O. Box 967 Carson City, Nv.

2. LOCATION 3450 1/4 Conte Dr Sec. 33 T. 15 N/S R. 20 E Carson City County
 PERMIT NO. _____

3.	TYPE OF WORK			4.	PROPOSED USE			5.	TYPE WELL	
	New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	Other <input type="checkbox"/>		Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>		Cable <input checked="" type="checkbox"/>	Rotary <input type="checkbox"/>
	Deepen <input type="checkbox"/>			Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>	Other <input type="checkbox"/>			

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Sandy Soil		0	2	2
Cemented Rock		2	8	6
Sandy Clay & Rock		8	14	6
Sand & Rock		14	16	2
Sandy Clay		16	64	48
Sand & Rock		64	68	4
Sandy Clay		68	122	54
Sand & Gravel	X	122	141	19
Sandy Clay		141	161	20
Sand & Rock	X	161	235	74
Sand & Boulders	X	235	246	11
Sandy Clay		246	261	15
Sand & Gravel	X	261	264	3
Clay		264	266	2
Sand & Gravel	X	266	270	4
Sandy Clay		270		

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 270 feet
 Casing record _____
 Weight per foot 19.40 Thickness 203

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>242</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Grout
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Mill Slot
 Size perforation 3/32 X 3"
 From 200 feet to 242 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 110 Feet below land surface
 Flow _____ G.P.M.
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Burgess & Rohe Drilling Co.
 Address 3320 Conte Dr. Carson City, Nv.
 Nevada contractor's license number 12278
 Nevada driller's license number 699
 Signed [Signature]
 Date 5-3-74

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed with Compressed Air			
Approx. 15 Gals. per minute			

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours