

Log No. 14102
Permit No. _____
Basin Eagle Valley

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Carson View Estates ADDRESS Lot # 23
5 - Sentinel Creek, Carson City, Nev.
2. LOCATION 5th 1/4 1/4 Sec. 28 T. 15 N. R. 20 E. Ormsby County
PERMIT NO. _____

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>fine sand</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Clay & sand</u>		<u>10</u>	<u>52</u>	<u>42</u>
<u>Clay</u>		<u>52</u>	<u>71</u>	<u>19</u>
<u>loam sand</u>	<u>w.B</u>	<u>71</u>	<u>74</u>	<u>3</u>
<u>Clay</u>		<u>74</u>	<u>124</u>	<u>50</u>
<u>loam sand</u>	<u>w.B</u>	<u>124</u>	<u>160</u>	<u>36</u>
<u>Clay</u>		<u>160</u>	<u>162</u>	<u>2</u>

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 16.2 feet
Casing record _____
Weight per foot _____ Thickness 1.58
Diameter From To
6 3/8 inches 0 feet 16.2 feet
_____ inches _____ feet _____ feet
Surface seal: Yes No Type Cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from _____ feet to _____ feet
Perforations:
Type perforation factory
Size perforation 3/2
From 126 feet to 162 feet
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 6.2 Feet below land surface
Flow _____ G.P.M. 20
Water temperature _____ ° F. Quality _____

Date started Nov 23, 1973
Date completed Nov 30, 1973

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 30 feet 2 hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
ENLOE DRILLING COMPANY
Name 1450 Valley View Drive
Carson City, Nevada 89701
Address _____
Nevada contractor's license number _____
Nevada driller's license number 586
Signed James Kouse
Date Dec 13, 1973