



Log No. 14139  
 Permit No. ....  
 Basin .....

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Pyramid Lake Tribal Enterprises ADDRESS Sutcliff, Nevada

2. LOCATION  $\frac{1}{4}$   $\frac{1}{4}$  Sec. 15 T. 24 N/S R. 21 E. Washoe County  
 PERMIT NO. ....

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Black to brown clay topsoil		0'	1'	1'
Loose 3/4" ang. grav. w/1' thick clay lenses, periodically-dark brown clay		1'	18'	17'
Loose 1" to 3/4" multi colored grav. w/coarse sand		18'	40'	22'
Orange clay w/multi colored grav. to 1/4" med. hard to hard		40'	77'	37'
Formation becomes slightly more brown-cuttings are lt. brown to reddish rock w/some upper grav.-multi colored to 1/4"		77'	107'	30'
Grav. remain same, clay very lt. gray-almost white		107'	110'	3'
Greenish rock-frac. med. hard to hard		110'	131'	21'
Brown reddish brown rock-hard w/lt. gray to greenish veins up to 1 1/2'		131'	198'	67'

8. WELL CONSTRUCTION  
 Diameter hole 6 inches Total depth 355 feet  
 Casing record 355'  
 Weight per foot 12.89 Thickness 1.88

Diameter	From	To
<u>6 5/8 OD</u> inches	<u>0</u> feet	<u>355</u> feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes  No  Type Cement grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from ..... feet to ..... feet

Perforations:  
 Type perforation Factory mill slot  
 Size perforation 5/32" x 2 1/2"  
 From 170 feet to 355 feet  
 From ..... feet to ..... feet

(Page 2)  
 Date started 5-21-74, 19.....  
 Date completed 5-27-74, 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Air blown</u>	<u>137 GPM @ 150'</u>		

9. WATER LEVEL  
 Static water level 66 Feet below land surface  
 Flow ..... G.P.M.  
 Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.  
P.O. Box 404  
 Address Sparks, Nevada 89431

Nevada contractor's license number 9767  
 Nevada driller's license number 493

Signed W.L. McDonald  
 Date 6-18-74

BAILER TEST  
 G.P.M. .... Draw down ..... feet ..... hours  
 G.P.M. .... Draw down ..... feet ..... hours  
 G.P.M. .... Draw down ..... feet ..... hours