

OFFICE USE ONLY  
 Log No. 14182  
 Permit No. ....  
 Basin.....

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Cleve Canepa ADDRESS 33 No. Sierra  
Empire, Nevada Reno, Nevada  
 2. LOCATION 1/4 Sec 18 T 29 N/S R 23 E Washoe County  
 PERMIT NO. 22?

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay-gray hardpan		0'	1'	1'
3/4" angular gravels w/sand lenses-no clay		1'	33'	32'
Gray clay (10%) w/ gravels to 1/2" (ang.)		33'	69'	36'
Brown sand w/gravels to 1/2" w/occas. cobbles		69'	107'	38'
Gravels to 3/4"-semi-angular, w/sand; fine to coarse and silt, 5%		107'	140'	33'

8. WELL CONSTRUCTION  
 Diameter hole 6 inches Total depth 140 feet  
 Casing record 140'  
 Weight per foot 12.89 Thickness 188  

Diameter	From	To
6 5/80D inches	0 feet	140 feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

 Surface seal: Yes  No  Type Cement grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from ..... feet to ..... feet  
 Perforations:  
 Type perforation Factory mill slot  
 Size perforation 5/32" x 2 1/2"  
 From 100 feet to 140 feet  
 From ..... feet to ..... feet

9. WATER LEVEL  
 Static water level 90 Feet below land surface  
 Flow ..... G.P.M.  
 Water temperature ..... ° F. Quality.....

Date started 5-14-74, 19.....  
 Date completed 5-15-74, 19.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air blown	24.75 @	125' - 135'	

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name W.L. McDonald & Co.  
P.O. Box 404  
 Address Sparks, Nevada 89431  
 Nevada contractor's license number 9767  
 Nevada driller's license number 493  
 Signed W.L. McDonald  
 Date 6-19-74

BAILER TEST

G.P.M.	Draw down	feet	hours