


WELL DRILLERS REPORT

Please complete this form in its entirety



1. OWNER Eddie B. Scott ADDRESS 1554 Pittman Street, Sparks, Nevada
Job Site: 2400 Walnut, Reno, Nevada
2. LOCATION SE 1/4 SW 1/4 Sec. 21 T. 11 N/S R. 21 E. Washoe County
PERMIT NO. _____

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Black Gumbo with Gravel		0	30	30
Clay & Gravel		30	39	9
Clay with small amt. of gravel....		39	50	11
Boulders & Clay	x	50	62	12
Hard Boulders	x	62	66	4
Blue Clay & Sand	x	66	110	44

Diameter of Hole: 18" to 50 ft.
12" from 50 to 110 ft.
Surface water from 5' to 50' sealed off
Concrete Plug, 108 to 110'

8. WELL CONSTRUCTION
Diameter hole.....inches Total depth 110 feet
Casing record..... Thickness.....
Weight per foot..... Thickness.....
Diameter 8 inches From 0 feet To 108 feet
..... inches feet feet
Surface seal: Yes No Type Cement
Depth of seal..... 50 feet
Gravel packed: Yes No
Gravel packed from..... 5 feet to..... 108 feet
Perforations:
Type perforation..... Torch
Size perforation..... 1/8 X 3
From..... 85 feet to..... 108 feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet

9. WATER LEVEL
Static water level..... 5 Feet below land surface
Flow..... G.P.M.
Water temperature..... ° F. Quality.....

Date started..... 6/17..... 1974
Date completed..... 6/24..... 1974

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name..... Burroughs of Nevada
Address..... 10310 Old Virginia City Road
Reno, Nevada 89502
Nevada contractor's license number..... 5092
Nevada driller's license number..... 751
Signed..... Auston W. Graham
Date..... 6/24/74

BAILER TEST
G.P.M. 30 plus Draw down..... 0 feet 2 hours
G.P.M. Draw down..... feet hours
G.P.M. Draw down..... feet hours