

Log No. 18230
 Permit No.
 Basin. Eagle Val

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Roland Hembree ADDRESS 1331 Koontz Lane
4369 Ponderosa Carson City, Nevada
 2. LOCATION 1/4 1/4 Sec. 32 T. 15 N/S R. 20 E Carson City County
 PERMIT NO.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Decomposed Granite	X	0	68	68
Sand	X	68	75	7
Sandy Clay		75	84	9
Decomposed Granite	X	84	90	6
Sandy Clay		90	104	14
Decomposed Granite	X	104	108	4
Sandy Clay		108	116	8
Decomposed Granite	X	116	120	4

8. WELL CONSTRUCTION
 Diameter hole 6-5/8 inches Total depth 120 feet
 Casing record.....
 Weight per foot 12.89 Thickness .188
 Diameter From To
6-5/8 inches 0 feet 120 feet
inchesfeetfeet
 Surface seal: Yes No Type Groute
 Depth of seal 55 feet
 Gravel packed: Yes No
 Gravel packed from.....feet to.....feet
 Perforations:
 Type perforation Mill Slot
 Size perforation 3/32 X 3"
 From 83.9 feet to 116.2 feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

9. WATER LEVEL
 Static water level 50 Feet below land surface.....
 Flow..... G.P.M.....
 Water temperature Cold ° F. Quality Good

Date started 7/12/74
 Date completed 7/15/74

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Burgess & Rohe Drilling Co.
 Address P.O. Box 132--Carson City, Nv.
 Nevada contractor's license number 12278
 Nevada driller's license number 757
 Signed Charles Rohe
 Date July 22, 1974

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Developed with compressed air</u>			
<u>Approx. 20 Gals. per minute</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours