

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY

Log No. 14237  
 Permit No. \_\_\_\_\_  
 Basin. Washoe Valley

1. OWNER Security Housing Corp. ADDRESS 151 Wonder Street  
Reno, Nevada 89501

2. LOCATION SW 1/4 SW 1/4 Sec. 4 T. 17 N/S R. 20 E. Washoe County  
 PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	2	2
Clay		2	8	6
Sandy clay		8	15	7
Gravel, sand, water		15	35	20
Sandy clay		35	40	5
Gravel & sand		40	50	10
Sandy gravel		50	70	20
Gravel, sand, lava dinders		70	94	24
Clay		94	96	2

8. WELL CONSTRUCTION  
 Diameter hole 6 inches Total depth 96 feet  
 Casing record \_\_\_\_\_  
 Weight per foot 12.89 Thickness 1.88  
 Diameter 6 5/8 inches From 0 feet To 96 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type cement  
 Depth of seal 51 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation Factory - mill cut  
 Size perforation 1/8" X 3"  
 From 72 feet to 92 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 2 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature cold ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Name Reno Pump & Supply  
7468 S. Virginia Street  
 Address Reno, Nevada 89502

Nevada contractor's license number 5307  
 Nevada driller's license number 285

BAILER TEST  
 G.P.M. 50 GPM Draw down 20 feet 4 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

Signed Hany W Jones  
 Date July 23, 1974