DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 14274
Permit No.
Basin Lemmon Val

1. OWNER MERLIN L. LENOX ADDRESS 1140 SOUTH CURRY
CARSON CITY, NEVADA 89701
DRILLED AT: 11500 VICKSBURG ROAD LOT 9 WASHOE RANCHES UNIT 4

2. LOCATION ¼ ¼ Sec. 24 T. 21 N/S R. 18 E. WASHOE County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
surface clay		0	18	18
sand & gravel		18	36	18
clay hard pan		36	64	28
hard sandstone	42	64	106	42
brown clay		106	154	48
brown sandy clay		154	180	26
sandstone with gravel, hard	63	180	243	63

Date started MAY 27, 1974
Date completed June 2, 1974

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 243 feet
Casing record 8 5/8 o.d.
Weight per foot 16 lbs Thickness 188wall

Diameter	From	To
12¼ inches	0 feet	243 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 60 to 40 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 60 feet to 243 feet

Perforations:
Type perforation Milled
Size perforation 2"
From 183 feet to 243 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 70 Feet below land surface
Flow G.P.M.
Water temperature 63 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name SAGE BROS DRILLING COMPANY
Address 1500 RANGER ROAD RENO, NV
Nevada contractor's license number 7462
Nevada driller's license number 615
Signed W. L. Sage
Date AUGUST 9, 1974

USE ADDITIONAL SHEETS IF NECESSARY

5471