DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 14279
Permit No. 27707
Basin LVAB

1. OWNER CLARK COUNTY ADDRESS CLARK COUNTY COURT HOUSE

PERMIT WELL WINTERWOOD GOLF COURSE

2. LOCATION SE ¼ NE ¼ Sec 9 T 21 N/S R 62 E CLARK County
PERMIT NO. 27707

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	50	50
CEMENTED GRAVEL		50	62	12
SAND + GRAVEL	✓	62	70	8
LARGE GRAVEL	✓	70	79	9
CEMENTED GRAVEL		79	88	9
RED STICKY CLAY		88	126	38
SAND + GRAVEL	✓	126	135	9
BROWN CLAY		135	148	13
GREEN CLAY		148	154	6
RED STICKY CLAY		154	166	12
SMALL GRAVEL	✓	166	172	6
BROWN CLAY		172	204	32
BLUE SHALE		204	240	36
RED SANDY CLAY		240	256	16
CEMENTED SAND		256	264	8
BROWN CLAY		264	286	12
CEMENTED SAND		286	297	11
GYPSUM		297	300	3

RECEIVED
AUG 12 1974
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 4-12, 1974
Date completed 7-2, 1974

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1800	340	180	48

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 24 inches Total depth 300 feet
Casing record 26" - 14" - 10"
Weight per foot 86 lbs - 46 lbs - 24 lbs Thickness 5/16 5/16 lbs

Diameter		From		To	
26	inches	0	feet	50	feet
14	inches	0	feet	245	feet
10	inches	240	feet	300	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type CEMENT GROUT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 240 feet to SURFACE feet

Perforations:
Type perforation MACHINE PERFORATED
Size perforation 3/16" X 2½ 10 ROWS
From 50 feet to 300 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 20 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN WATER WELL SERVICE
Address P.O. Box 15149 LAS VEGAS 89114
Nevada contractor's license number 5095
Nevada driller's license number 40
Signed [signature]
Date 8-8-74

USE ADDITIONAL SHEETS IF NECESSARY

5471