

OFFICE USE ONLY  
 Log No. 1A 299  
 Permit No. \_\_\_\_\_  
 Basin Truckee Meadows

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Security Housing Corp. ADDRESS 151 Wonder Street  
Reno, Nevada 89501

2. LOCATION SW 1/4 NW 1/4 Sec. 15 T. 21 N. 19 R. 19 E. Washoe County  
 PERMIT NO. \_\_\_\_\_

3.	TYPE OF WORK		4.	PROPOSED USE			5.	TYPE WELL	
	New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>		Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>		Cable <input checked="" type="checkbox"/>	Rotary <input type="checkbox"/>
	Deepen <input type="checkbox"/>	Other <input type="checkbox"/>	Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>		Other <input type="checkbox"/>		

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay		0	65	65
Sandy clay w/ hard rock layer		65	110	45
Sandy clay		110	138	28
Coarse sand w/ water		138	155	17
Sandy clay		155	200	45
Sandy clay		200	225	25
Sandy clay		225	250	25

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 250 feet  
 Casing record \_\_\_\_\_  
 Weight per foot 12.89 Thickness 1.88

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>250</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type cement  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation Factory - mill cut  
 Size perforation 1/8" X 3"  
 From 219 feet to 242 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level XII 135 Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature cold ° F. Quality \_\_\_\_\_

Date started August 6, 19 74  
 Date completed August 14, 19 74

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 15 Draw down 15 feet 2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Reno Pump & Supply  
 Address 7468 S. Virginia St. - Reno  
 Nevada contractor's license number 5307  
 Nevada driller's license number 285  
 Signed Harry W. Jones  
 Date August 23, 1974