DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 14382
Permit No.
Basin Truckee Meadows

1. OWNER Security Housing Corporation ADDRESS 161 Wonder Street - Reno, 89502

For location - see attached

2. LOCATION ¼ ¼ Sec. T. N/S R. E. County
PERMIT NO.

3. TYPE OF WORK
New Well XX Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	20	20
Yellow/Clay		20	45	25
Sand & Gravel		45	65	20
Sand & Gravel		65	86	21
Blue clay		86	91	5

Date started October 11, 1974
Date completed October 15, 1974

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 4 feet 1½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 91 feet
Casing record
Weight per foot 12.89 Thickness .188

Diameter		From		To	
6 5/8	inches	0	feet	91	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory - Mill cut
Size perforation 1/8" X 3"
From 63 feet to 82 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 8 Feet below land surface
Flow G.P.M.
Water temperature cold F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Reno Pump & Supply
Address 7468 S. Virginia St.
Nevada contractor's license number 5307
Nevada driller's license number 285
Signed Harry W. Jones
Date October 17, 1974

USE ADDITIONAL SHEETS IF NECESSARY 5471