DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 14401
Permit No.
Basin Eagle Valley

1. OWNER Carson View Estates ADDRESS Box 755 Zephyr Cove, Nev

2. LOCATION ¼ ¼ Sec. 28 T. 15 N/S R. 20 E. Carson City County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	8	8
D. G.		8	20	12
D. G. with Clay		20	35	15
Sandy Clay		35	50	15
Cemented D. G.		50	64	14
Sandy Clay		64	78	14
Sand	✓	78	80	2
Sandy Clay		80	84	4
Cobbles in Clay		84	90	6
Cemented D. G.		90	100	10
Alt. Layers Sand & Clay		100	176	76

Date started Aug 15, 1974
Date completed Aug 20, 1974

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	20	55	12

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 176 feet
Casing record
Weight per foot 13 LBS Thickness .188

Diameter	From	To
6 5/8 inches	41 feet	176 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 ft feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 176 feet

Perforations:
Type perforation Milled
Size perforation 3/32 x 2½
From 114 feet to 176 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 55 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ENLOE DRILLING COMPANY
Address 1450 Valley View Drive
Carson City, Nevada 89701
Nevada contractor's license number 4739
Nevada driller's license number 249
Signed Floyd Enloe
Date Oct 26-74

USE ADDITIONAL SHEETS IF NECESSARY

5471