

WELL DRILLERS REPORT

Please complete this form in its entirety

Log No. 14476
 Permit No. _____
 Basin Washoe Meadows
 688

1. OWNER Wagner Construction ADDRESS 1730 Kirman Ave.
Reno, Nevada

2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 2 T. 17N N/S R. 20E Washoe County
 PERMIT NO. (Lot 33; Galena Terrace Estates)

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
loamy topsoil		0	1	1
Hard brown clay		1	4	3
Hard granite boulder		4	6	2
Coarse decomposed granite sand w/ 2% boulders to 2' diameter		6	80	74
Fine to coarse silty brown sand. Occasional cobbles to 10" diam. Inconsistently water bearing		80	110	30
Coarse sand w/ semi-rounded gravels to 1" diam. & 5% cobbles to 10% diameter		110	115	5

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 115 feet
 Casing record 0-115 X 6 5/8 OD
 Weight per foot 12.82 Thickness 1.88

Diameter	From	To
10 inches	0 feet	52 feet
8 inches	52 feet	115 feet

Surface seal: Yes No Type transit mix
 Depth of seal 52 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation oxy-acet. torch
 Size perforation 3/16 X 5"
 From 85 feet to 115 feet
 From _____ feet to _____ feet

Date started 12-3-74, 19____
 Date completed 12-4-74, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>AIR BLOWN</u>	<u>10GPM @</u>	<u>105' depth</u>	
	<u>16GPM @</u>	<u>115' depth</u>	

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours


9. WATER LEVEL

Static water level 80 Feet below land surface
 Flow _____ G.P.M.
 Water temperature cold ° F. Quality not tested

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
 Address P.O. Box 404; Sparks, Nevada
 Nevada contractor's license number 9767
 Nevada driller's license number 493
 Signed W.L. McDonald
 Date 12-9-74



26 11 11 11 11 11

11 11 11 11 11 11