DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 14568
Permit No. 28954
Basin Sandy LV

1. OWNER BELL TELL Co. ADDRESS SANDY VALLEY

2. LOCATION S-E ¼ S-W ¼ Sec. 31 T. 24 N/S R. 57 E County
PERMIT NO. 28954

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0'	4'	4'
W-CALICHE		4'	12'	8'
SAND & CALICHE STR	X	12'	36'	24'
CALICHE		36'	39'	3'
SAND & CALICHE	X	39'	52'	13'
SAND		52'	54'	2'
CLAY & SAND, STR'G	X	54'	78	24'
CLAY		78'	81'	3'
CLAY & SAND	X	81'	96'	15'
CALICHE		96'	98	2'
SANDY CLAY		98'	106	8'
SAND	X	106'	112'	6'
SANDY CLAY		112'	120	8'
CALICHE		120'	122'	2'
SANDY CLAY	X	122'	137'	15'
SAND	X	137'	140'	3'
LIMESTONE		140'	145'	5'
CLAY		145'	150'	5'
LIME STONE		150'	155'	5'
SANDY CLAY	X	155'	162'	7'
CLAY & LIME STONE		162'	185'	23'
GRAVEL	X	185	187	2'
LIMESTONE		187'	195	8'
SANDY CLAY	X	195	200	5'

RECEIVED
FEB 3 1975
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 11-5- 19 74
Date completed 11-19- 19 74

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 42 Draw down 32 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 ¼ inches Total depth 200 feet
Casing record
Weight per foot 12.75 Thickness .16.646

Diameter	From	To
8 5/8 inches	0 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 60 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 60 feet to 200 feet

Perforations:
Type perforation TORCH CUT
Size perforation 4" x 12" 2 ROWS
From 120 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 19 Feet below land surface 19
Flow G.P.M.
Water temperature COOL ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Floyd Pump & Drilling
Address P.O. BOX 32 A PAHRUMP NEV.
Nevada contractor's license number 12344
Nevada driller's license number 643
Signed Wayne L. Floyd
Date 1-19-75

USE ADDITIONAL SHEETS IF NECESSARY

5471

Replaced by well log 123486