

OFFICE USE ONLY
 Log No. 14614
 Permit No. 26684
 Basin Imley Area

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER John King (Stuckeys) ADDRESS Imley, Nev.
 2. LOCATION SW 1/4 NE 1/4 Sec 5 T. 22 N/S R. 34 E. Pershing County
 PERMIT NO. 35

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	2	2
Clay + Rock Mixed		2	30	28
Br. Clay + Cobbles		30	91	61
Cemented Gravel		91	215	124
Loose Gravel		215		

Original Copy in Permit File

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 215 feet
 Casing record.....
 Weight per foot..... Thickness.....

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>215</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

 Surface seal: Yes No Type Cement
 Depth of seal..... feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet
 Perforations:
 Type perforation Mills
 Size perforation 3/8 x 2
 From 180 feet to 215 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

9. WATER LEVEL
 Static water level..... Feet below land surface.....
 Flow..... G.P.M.....
 Water temperature..... ° F. Quality.....

Date started May 12 1972
 Date completed May 15 1972

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>15</u>	<u>200</u>	<u>2 hrs</u>
			<u>Test</u>

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Armstrong Bros.
 Address 4710 Highway 40 West
 Nevada contractor's license number 5348
 Nevada driller's license number 619
 Signed Armstrong Bros
 Date June 10, 1972

BAILER TEST
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours