

OFFICE USE ONLY  
 Log No. 11680  
 Permit No. 29031  
 Basin Des Val  
31303

WELL DRILLERS REPORT

Please complete this form in its entirety

19-3

1. OWNER Key Management, Inc. ADDRESS 40 Mary Street  
Reno, Nevada 89501

2. LOCATION SW 1/4 SE 1/4 Sec 19 T. 36 N S R. 34 E Humbolt County  
 PERMIT NO. 29031

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand and gravel		0	30	
Sand, gravel and rock clay		30	62	
		62	78	
Sand and gravel		78	103	
Clay and gravel		103	105	
Sand gravel and rock		105	228	
Galy with gravel		228	244	
Gravel and rock		244	281	
Clay		281	286	
Gravel and rock		286	296	
Decomposed gravel		296	301	
Gravel and rock		301	310	

8. WELL CONSTRUCTION  
 Diameter hole 22 inches Total depth 310 feet  
 Casing record.....  
 Weight per foot 48 Lb. Thickness 3/16  

Diameter	From	To
<u>14.00</u> inches	<u>0</u> feet	<u>310</u> feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

 Surface seal: Yes  No  Type.....  
 Depth of seal..... feet  
 Gravel packed: Yes  No   
 Gravel packed from 0 feet to 310 feet  
 Perforations:  
 Type perforation Louwer  
 Size perforation 1/8" Standard  
 From 142 feet to 310 feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

Date started March 15, 1975  
 Date completed March 17- 1975

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>1600</u>	<u>15 1/2'</u>	<u>8</u>
	<u>1150</u>	<u>10</u>	<u>8</u>
	<u>850</u>	<u>7 1/2</u>	<u>8</u>

BAILER TEST  
 G.P.M. .... Draw down..... feet ..... hours  
 G.P.M. .... Draw down..... feet ..... hours  
 G.P.M. .... Draw down..... feet ..... hours

9. WATER LEVEL  
 Static water level 57' Feet below land surface  
 Flow..... G.P.M.  
 Water temperature..... ° F. Quality.....

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Bobby Joe Cunningham  
 Address Box 1224  
Ben Barrow Co Inc  
 Nevada contractor's license number 12852  
 Nevada driller's license number 765  
 Signed Bobby Joe Cunningham  
 Date 18 March 75