DIVISION OF WATER RESOURCES

Plugged by Log No. 112155

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 14696
Permit No.
Basin 110 A

1. OWNER INDIAN Health Service ADDRESS Schurz, Nevada

2. LOCATION SW ¼ NE ¼ Sec. 35 T. 13 N/S R. 28 E. MINERAL County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COBBLES IN D.G.		0	4	4
D.G. SAND		4	7	3
COBBLES IN D.G		7	20	13
BROWN CLAY & COBBLES		20	30	10
D.G & COBBLES		30	40	10
BROWN CLAY TRACE D.G		40	60	20
COBBLES IN D.G		60	65	5
CLAY - TRACE OF D.G		65	70	5
SANDY CLAY -		70	90	20
COBBLES -		90	93	3
CLAY -		93	95	2
COBBLES & SAND -		95	104	9
COBBLES IN SANDY CLAY		104	125	21
BROWN CLAY WITH LAYER SAND & GRA		125	205	80
BROWN CLAY WITH COBBLES		205	215	10
BROWN SANDY CLAY		215	245	30
COARSE SAND IN CLAY		245	250	5
CLAY WITH COARSE GRAV		250	255	5
BLUE CLAY - TRACE OF SAND		255	325	70
CLAY WITH THIN LAYERS OF GRAV		325	350	25
SAND GRAV. TRACE OF CLAY -		350	370	20

Date started Jan 14, 1975
Date completed MARCH 29, 1975

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	130	49	9

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 14" inches Total depth 370 feet
Casing record
Weight per foot 31.2 LBS Thickness .279

Diameter	From	To
10 inches	+ 2 feet	350 feet
8 BLANK inches	345 feet	350 feet
8" SCREEN inches	350 feet	365 feet
8" BLANK inches	365 feet	370 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 3 - 28 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 28 feet to 370 feet

Perforations:
Type perforation .070 Johnson Screen
Size perforation
From 350 feet to 365 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 56 Feet below land surface
Flow G.P.M.
Water temperature 61 ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ENLOE DRILLING COMPANY
1450 Valley View Drive
Address Carson City, Nevada 89701
Nevada contractor's license number 4739
Nevada driller's license number 249
Signed [signature]
Date 4/2/75

USE ADDITIONAL SHEETS IF NECESSARY

5471