

OFFICE USE ONLY  
 Log No. 14776  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Robert Benevisea ADDRESS Pleasant Valley Nevada

2. LOCATION SW 1/4 SW 1/4 Sec. 29 T. 33 N/S R. 57 E Elko County  
 PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silt</u>		<u>0</u>	<u>3</u>	
<u>Granite gravel</u>		<u>3</u>	<u>44</u>	
<u>fine gravel &amp; clay</u>		<u>44</u>	<u>83</u>	
<u>Sand &amp; clay</u>		<u>83</u>	<u>85</u>	
<u>clay</u>		<u>85</u>	<u>100</u>	
<u>loose gravel 1' to 2" x 200</u>			<u>130</u>	
<u>clay</u>		<u>130</u>		

8. WELL CONSTRUCTION  
 Diameter hole 6 inches Total depth 135 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 250  

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>135</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 100 feet  
 Perforations:  
 Type perforation Torch cut  
 Size perforation 3/8" x 4"  
 From 105 feet to 135 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 100 Feet below land surface 100  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature cell ° F. Quality Good

Date started 5/16/75, 1975  
 Date completed 5/19/75, 1975

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name J. B. Reynolds  
 Address Fallon, Nevada  
 Nevada contractor's license number 3718  
 Nevada driller's license number 74F  
 Signed J. B. Reynolds  
 Date 5/24/75

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down 10 feet 3 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours