DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 14788
Permit No. 27666
Basin Eagle Valley

1. OWNER Mel Courtwaite ADDRESS 1950 ash Canyon Road Carson City, Nevada

2. LOCATION ¼ SW ¼ Sec. 7 T. 15 N/S R. 20 E. Ormsby County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
~~[illegible]~~				
Top Soil		0	6	6
Loose Sand		6	16	10
Yellow Sand & Clay		16	46	30
Coarse Sand	W.B.	46	49	3
Red Clay & Sand		49	64	15
Coarse Sand	W.B	64	95	31
Brown Clay		95	100	5

Plugged by NOI # 58675

(TA)

39.176510°N
119.784207°W
NAD 27

Date started March 13, 1974
Date completed March 16, 1974

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 25 Draw down 20 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 100 feet
Casing record 8 5/8 O D
Weight per foot Thickness .188

Diameter	From	To
8" inches	0 feet	100 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 46 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 7/32"
From 60 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 50 Feet below land surface
Flow G.P.M. 25
Water temperature Cool ° F. Quality Clear

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name James House
Address P O Box 351
Nevada contractor's license number
Nevada driller's license number 586
Signed James House
Date April 10, 1974

USE ADDITIONAL SHEETS IF NECESSARY

5471