

Log No. 14808  
 Permit No. \_\_\_\_\_  
 Basin Boulder Flot

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER T. LAZY S RANCH ADDRESS BATTLE MTN. NV.

2. LOCATION NW 1/4 SW 1/4 Sec 26 T. 33 N/S R. 49 E EUREKA County  
 PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material           | Water Strata | From | To  | Thick-ness |
|--------------------|--------------|------|-----|------------|
| SANDY SOIL         |              | 0    | 15  | 15         |
| ALLUVIUM           |              | 15   | 80  | 65         |
| LAVA (Dense, hard) |              | 80   | 200 | 120        |
| YELLOW CLAY        |              | 200  | 205 | 5          |
| LAVA               |              | 205  | 245 | 40         |
| CLAY & BROKEN LAVA |              | 245  | 250 | 5          |
| LAVA               |              | 250  | 310 | 60         |
| CEMENTED SAND      | Sgph         | 310  | 375 | 65         |
| LAVA (dense, hard) |              | 375  | 376 | 1          |
| T.D. 5/30/75       |              | 376  |     |            |

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 376 feet  
 Casing record 378 ft 6 5/8  
 Weight per foot 12.78 Thickness 1.55

| Diameter     | From       | To         |
|--------------|------------|------------|
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes  No  Type \_\_\_\_\_  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation 1/8" x 3"  
 Size perforation \_\_\_\_\_  
 From 230 feet to 250 feet  
 From 336 feet to 376 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level unk Feet below land surface  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

Date started 5/27, 1975  
 Date completed 5/31, 1975

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

BAILER TEST

G.P.M. 4 to 5 g.p.hour Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHET WEAVER (Muth Drilling Co.)  
 Address 203 Pine Street  
Elko, Nevada 89801  
 Nevada contractor's license number 10819  
 Nevada driller's license number WEAVER 670, MUTN 632  
 Signed James V Muth  
 Date 6/15/75